

पत्रांक-820/

दिनांक-05.03.2024

प्रेषक :-

कार्यपालक अभियंता  
लोक स्वा0 प्रमंडल मुंगेर।

सेवा में,

प्रिंसीपल  
अवधुत. एकेडमी मुंगेर।

विषय :- सुरक्षित पेयजल तथा स्वाच्छता हेतु प्रमाण पत्र के संबंध में।

प्रसंग :- आपका रेफरेन्स Area/ Mgr/L No-233 दिनांक-23.02.2021।

महाशय,

उपर्युक्त विषयक प्रासंगिक पत्र के आलोक में उक्त संस्थान का जिला जल जाँच प्रयोगशाला द्वारा पेयजल नमूनों को जाँचा गया, जिसे मानक के अनुरूप पाया गया।

अनुलग्नक :- जिला जल जाँच प्रतिवेदन

विश्वास भाजन

कार्यपालक अभियंता लोक  
स्वा0 प्रमंडल मुंगेर।

09.03.24

Government of Bihar  
Public Health Engineering Department  
District Level Water Testing Laboratory Munger  
Water Quality Monitoring Report

District Munger

Ref no Arealngri.No. 233 Dated 23.02.21

Month February 2021

Sl. No.	Particulars					Test Result (in mg/l)														Total Coliform (MPN count.)	Type of Contamination	Remarks Safe /Unsafe
	Block Name	Panchyat Name	Village	Tola ward no	Name of Source/Caretaker	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alk	Fe	NO <sub>3</sub>	SO <sub>4</sub>	F	As			
1	Munger Sadar	Municipa l Area	Bindwara	Not Available	Awadhoo t Academy	7.23	0.1	749	487	392	124	20	39	411	0.1	5	24	0.62	BDL	NIL		
Desirable Limit					5.5 to 8.5	1		500	200	75	30	250	200	1	45	200	1.0	0.010	0.000			
Maximum Permissible limit.					NR	10.0		2000	600	200	175	1000	600	NR	NR	400	1.50	NR	0/100 ml			

Note Parametric abbreviations stands as EC Electric Conductivity, TDS Total Dissolved Solid, TH Total Hardness, F Fluoride, As Arsenic, MPN Maximum Possible number for Total Coli, BDL Below Detection limit etc. All the parameters tested in this laboratory are found within the maximum permissible limit. NR Not Releaxable

*P.H.*  
Chemist  
09.03.21  
P.H.Division, Munger

पत्रांक:- 2781/सू०

दिनांक:- 01-10-19

कार्यालय नगर निगम, मुंगेर

प्रेषक,

नगर आयुक्त  
नगर निगम, मुंगेर।

सेवा में,

प्राचार्य  
अवधुत एकेडमी  
मुंगेर- जमालपुर रोड, बिंदवारा, मुंगेर।

विषय:- एन०ओ०सी० प्राप्त करने के संबंध में।

प्रसंग:- आपका पत्रांक-Awa/Mgr/L.no-202/2019-20

महाशय,

उपरोक्त विषय के संबंध में कहना है कि अवधुत एकेडमी के निरीक्षण के कम में सफाई की व्यवस्था संतोषजनक पाई गयी।

01.10.19  
नगर आयुक्त  
नगर निगम, मुंगेर।

